

# APPROVAL FOR CONSTRUCTION

THE PLANS AND SPECIFICATIONS FOR SEWAGE OR WASTE DISPOSAL SYSTEM SUBMITTED FOR:

APPROVAL # 134827

Owner:

John Cesar  
c/o Morgado, 14 Ledge Rd.  
Seabrook, NH 03874

LOT NUMBERS: 12  
SUBD. APPL. #: 12469  
SUBD. NAME:

Copy of Plan & Approval sent to:

Board of Selectmen  
Town Office  
Seabrook, NH 03874

TYPE OF SYSTEM:

3 bdr.

TOWN/CITY LOCATION: Seabrook  
STREET LOCATION: Ledge Rd.

By Applicant: PERMIT # 348

Anne W. Bialobrzewski  
247 Landing Rd.  
Hampton, NH 03842

PLEASE POST IN A CONSPICUOUS PLACE DURING CONSTRUCTION.

THIS APPROVAL DOES NOT SUPERCEDE ANY EQUIVALENT OR MORE STRINGENT LOCAL ORDINANCES OR REGULATIONS. STATE STANDARDS ARE MINIMAL AND MUST BE MET STATEWIDE.

WHITE= Applicant's; YELLOW= Town's; BLUE= NHWS&PCC file; GOLD= Owner's - (No Action Required)

NOTE: ( X ) Gravity system ( ) Gravity system to septic tank and effluent pump chamber with disposal system to be constructed on a properly prepared base.

Bed bottom to be set: ( ) no deeper than " below the original grade  
( X ) no less than 32 " above the original grade  
( ) no lower than the original grade

to maintain ( X ) 4 ' minimum above (the reported) (any) seasonal high water table.  
( ) ' minimum above (the reported) (any) ledge depth.  
( ) ' minimum above (the reported) (any) impermeable soil.

( X ) Fill to prepare disposal area should be a medium to coarse sand (0.5 to 1.0 mm).  
( ) This approval only valid for the above owner's domicile/exemption.

CONDITIONS: Foundation drains are not permitted. Installation of foundation drains shall void this approval.

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES IN PLANS AS INDICATED ON THIS CONDITIONAL APPROVAL.

are approved this date: June 6, 1986  
Thomas A. Lauher/blw

By: *Tom Lauher*  
N.H. Water Supply & Pollution Control  
Commission Staff (OVER)

Revised 8/1/80

INSPECTED BY  
G. MINNICK  
NHWS&PCC  
6/23/76

\*PIT#1 AND PERC DATA FROM APPROVED SUBDIVISION PLAN

## PERC TEST

DATE: 7/15/76

DEPTH OF HOLE: 28"

RATE OF PERC: 20 \* MIN/IN

DESIGN LOADING: 3 BEDROOMS

AREA REQUIRED: 1120 SQ. FT.

PROPOSED SYSTEM: 25' x 45' FOR

1125 SQ. FT. AREA PROVIDED

REVIEWED AND APPROVED IN ACCORDANCE WITH THE REQUIREMENTS OF THE

WATER SUPPLY & POLLUTION CONTROL COMMISSION

Signed  
Date

PLAN OF PROPOSED SEPTIC SYSTEM

ADVISE YOUR CONTRACTOR OF REQUIRED CHANGES IN PLANS AS INDICATED ON THIS CONDITIONAL APPROVAL.

LOT 12 LEDGE RD  
SEABROOK, NH.

OWNER: JOHN CESAR


90 MORGADO 14 LEDGE RD  
SEABROOK, NH 03874

APPLICANT: ANNE W. BIALOBRZESKI  
247 LANDING ROAD  
HAMPTON, N.H. 03842  
DESIGNER PERMIT #348

DATE: 5/5/86

APPROVAL:

68





S 21-43-00 E  
17.32  
CALC

S 87-15-19 W # 21(503) FND SB  
4988.112 TO WELL  
5455.684 DISTURB  
(PLAN 442.43)  
441.75

enjoy 0.16  
CH 589-54-32 E  
L=51.61  
R=500  
# 2(502) SETHUB  
5011.305  
5650.205

ORIGINAL  
CAL COR  
4998.146  
5656.252

LOCKES  
DRIVE

CAL COR 1706  
4995.268  
5656.608

CAL 4995.216  
5656.613

14 E N 87-18-17 E - 390.39

INTER  
4987.391  
5435.902

INTER  
4988.334  
5455.938  
4993.036  
5555.827

PC  
4995.350  
5604.969

99203  
2.3 AC

4754.480  
5356.767

942 AC  
LOT 16

INTER  
4565.714  
5488.132

INTER 227  
4566.282  
5508.214  
100.00

779  
4568.832  
5608.181

85.400  
2.0

42472

LOT 17

42953

LOT 18

12

42710

430.00  
N 01-03-39 W

1837  
3024

# 3(504) SETHUB  
4718.972  
5716.611

# 4(505) FND HUB  
4571.407  
5709.108  
CAL 4571.355  
5709.114

# 51(508) FND SB DISTURBED  
4565.246  
5487.471

# 5(507) SETHUB  
4568.084  
5506.158

# 41(506) SETHUB  
4416.940  
5725.045

# 42(531) SETHUB ENDWELL  
4375.044  
5732.767

# 43(532) FND DH  
4252.968  
5748.550

N 01-03-39 W  
520.87  
(PLAN 320.82)  
USE

554-42-03  
0.81

509)  
TTK ROOT  
6.025  
03.312

54

55

56

57

123.09  
N 01-22-40



